

Certificate

Registration No.: PV 50234605

Page 1

Report No.: 15051336.004

License Holder:

PV Solarsys, s.r.o
SNP 6
04442 Rozhanovce
Slovakia

Product:

PV Module Types:

With 6" poly c-Si cells:
PP xxx 3BB(xxx= 215-245, in steps of 5,60 cells)

Manufacturing Plant:

0001-15051336.001

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- **Qualified, IEC 61215**
- **Safety tested, IEC 61730**
- **Periodic inspection**

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**
- The fire test (IEC 61730-2 / MST 23) was not performed.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 15 July 2017.

Certification body



13 September 2012

Dipl.-Ing. (FH) Bernd Scheirer

TÜV Rheinland LGA Products GmbH, Tillystrasse 2, D-90431 Nürnberg
Contact: + (+49) 221 806-1371 email: cert-validity@de.tuv.com